

Classification Report

Number	21-001171-PR01 (NW-A01-02-en-01)
Owner	Smaj produkt d.o.o. Lazarevo selo bb 18110 Nis Serbia
Product	Double tilt and turn window with opening meeting stile
Designation	System: ALD SMAJ
Details	Manufacturer Smaj produkt d.o.o., Nis; Material Wood-aluminium; Type of opening Turn / tilt and turn; Opening direction Active casement DIN right (opening) to the inside, Inactive casement DIN left (opening) to the inside; Overall dimensions (W x H) 1400 mm x 1400 mm
Special features	Glass bonding: weiss - COSMO HD-200.101

Result

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C5/B5

Watertightness according to EN 12208:1999-11



Class: 9A

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 21-001171-PR01 PB-A01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim
13.03.2021



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Daniel Gromotka, B.Eng.
Operating Testing Officer
Building Component Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: BF5-D586C